

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332300457  
**DATE** : 16.02.2023  
**REQ No** : 1032300563  
**REQ TITLE** : Service PR for D-ST(Internal  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.02.2023  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
1		ITEM-00001	INTERNAL RUBBER LINING OF PH1 GENERATOR SEA WATER COOLING OUTLET SPOOL PIECES (8" PIPE, 1 METER HEIGHT WITH TWO NOZZLE OF SIZE 2 " F LANGE), MAIN OUTLET ELBOW (10" SIZE WITH JIS 5K FLANGES), MAIN CONDENSER SEAWATER INLET PIPE DRAIN LINE ELBOW (2" WITH FLANGE) AS PER SAMPLE AVAILABLE. LINING MATERIAL-NBR, HARDNESS: SHORE A -65-70, THICKNESS-3MM SCOPE OF WORK: 1. COLLECTION OF SAMPLE FROM DEWA SITE. 2. SAND BLASTING PIPE INNER SURFACE TO BE PREPARE SUITABLE FOR RUBBER LINING. 3. APPLYING OF PRIMER AND FINAL EPOXY COATING O F SPOOL EXTERNAL AREA. 4. AFTER RUBBER LINING QUALITY TEST TO APPROVE THE JOB (SPARK TEST) NEED TO BE CONDUCT. 5. MINIMUM 2 YEARS WARRANTY ON SERVICE HAS TO BE PROVIDE. 6. FINAL PRODUCT SHOULD BE CONFIRMED BY THE DEWA ENGINEER, IF ANY DEVIATIONS IS THERE, SHOULD A	4	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332300457  
**DATE** : 16.02.2023  
**REQ No** : 1032300563  
**REQ TITLE** : Service PR for D-ST(Internal  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.02.2023  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			TTEND IMMEDIATELY. CONTACT FOR SITE VISIT/ASSESSMENT. ABDULLAH-0526970925,HAJI.SHAIK@DEWA.GOV.AE						
2		ITEM-00001	INTERNAL RUBBER LINING OF PH1 GENERATOR SEA WATER COOLING OUTLET SPOOL PIECES (8" PIPE, 1 METER HEIGHT WITH TWO NOZZLE OF SIZE 2 " F LANGE), MAIN OUTLET ELBOW (10" SIZE WITH JIS 5K FLANGES), MAIN CONDENSER SEAWATER INLET PIPE DRAIN LINE ELBOW (2" WITH FLANGE) AS PER SAMPLE AVAILABLE. LINING MATERIAL-NBR, HARDNESS: SHORE A -65-70, THICKNESS-3MM SCOPE OF WORK: 1. COLLECTION OF SAMPLE FROM DEWA SITE. 2. SAND BLASTING PIPE INNER SURFACE TO BE PREPARE SUITABLE FOR RUBBER LINING. 3. APPLYING OF PRIMER AND FINAL EPOXY COATING O F SPOOL EXTERNAL AREA. 4. AFTER RUBBER LINING QUALITY TEST TO APPROVE THE JOB (SPARK TEST) NEED TO BE CONDUCT. 5. MINIMUM 2 YEARS WARRANTY ON SERVICE HAS TO BE PROVIDE. 6.	1	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332300457  
**DATE** : 16.02.2023  
**REQ No** : 1032300563  
**REQ TITLE** : Service PR for D-ST(Internal  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.02.2023  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			FINAL PRODUCT SHOULD BE CONFIRMED BY THE DEWA ENGINEER, IF ANY DEVIATIONS IS THERE, SHOULD ATTEND IMMEDIATELY. CONTACT FOR SITE VISIT/ASSESSMENT. ABDULLAH-0526970925,HAJI.SHAIK@DEWA.GOV.AE						
3		ITEM-00001	INTERNAL RUBBER LINING OF PH1 GENERATOR SEA WATER COOLING OUTLET SPOOL PIECES (8" PIPE, 1 METER HEIGHT WITH TWO NOZZLE OF SIZE 2 " F LANGE), MAIN OUTLET ELBOW (10" SIZE WITH JIS 5K FLANGES), MAIN CONDENSER SEAWATER INLET PIPE DRAIN LINE ELBOW (2" WITH FLANGE) AS PER SAMPLE AVAILABLE. LINING MATERIAL-NBR, HARDNESS: SHORE A -65-70, THICKNESS-3MM SCOPE OF WORK: 1. COLLECTION OF SAMPLE FROM DEWA SITE. 2. SAND BLASTING PIPE INNER SURFACE TO BE PREPARE SUITABLE FOR RUBBER LINING. 3. APPLYING OF PRIMER AND FINAL EPOXY COATING ON F SPOOL EXTERNAL AREA. 4. AFTER RUBBER LINING QUALITY TEST TO APPROVE THE JOB	2	EA				

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332300457  
**DATE** : 16.02.2023  
**REQ No** : 1032300563  
**REQ TITLE** : Service PR for D-ST(Internal  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.02.2023  
**CLOSING TIME** : 10:00:00

SL NO	ITEM CODE	SERVICE ID	DESCRIPTION	QTY	UOM	BRAND/ORIGIN	WARRANTY	UNIT PRICE	TOTAL PRICE
			(SPARK TEST) NEED TO BE CONDUCT. 5. MINIMUM 2 YEARS WARRANTY ON SERVICE HAS TO BE PROVIDED. 6. FINAL PRODUCT SHOULD BE CONFIRMED BY THE DEWA ENGINEER, IF ANY DEVIATIONS IS THERE, SHOULD ATTEND IMMEDIATELY. CONTACT FOR SITE VISIT/ASSESSMENT. ABDULLAH-0526970925,HAJI.SHAIK@DEWA.GOV.AE						

TOTAL AMOUNT IN WORDS:

TOTAL AMOUNT:

### **SPECIAL NOTES / INSTRUCTIONS:**

Service PR for D-ST(Internal rubber lining of Ph1 Generator Sea water cooling outlet spool pieces,Condenser drain line elbow(2" size with flanges). Contact Person: Haji Abdulla Shaik / haji.shaik@dewa.gov.ae / 04-32-26175 / +971526970925

### **STANDARD TERMS & CONDITIONS**

1) Prices should be 'DDP' delivery duty paid at DEWA stores.

**MATERIAL AND OR SERVICE PROVIDED TO DEWA SHOULD PREFERABLY BE ENERGY EFFICIENT AND ENVIRONMENT FRIENDLY.**

Page4 of 5

## REQUEST FOR QUOTATION LOCAL PURCHASE SECTION

**RFQ NUMBER** : 2332300457  
**DATE** : 16.02.2023  
**REQ No** : 1032300563  
**REQ TITLE** : Service PR for D-ST(Internal  
**DELIVERY LOCATION**  
**CLOSING DATE** : 22.02.2023  
**CLOSING TIME** : 10:00:00

- 2) Quotation to be submitted only in local currency U.A.E Dirhams
- 3) DEWA Standard payment terms is '30 days credit' from the date of acceptance of material
- 4) No DEWA staff or his or her relatives up to third degree should have ownership or partnership in your company, and your participation in DEWA tenders / RFQs should not constitute a Conflict or perceived Conflict of Interest.
- 5) The offered product and/ or services in the Quotation, shall be conforming and in accordance with DEWA Energy Management Policy & EnMS Manual.

**SUPPLIER'S REMARKS :**

**SUPPLIER'S SIGNATURE AND STAMP**